U.S.S.GEN I

E01-SAA29PP129-001

-SAA25PF125-001-

Sheet 7 of 8

B/L: 72.06 72.63

SYS: Fuel Cell

Deservicing MAY 1 9 1992

Critical Item: Check Valve (| Item Total)

Find Number: A106656

Criticality Category: 15

SAA No: 29PP129-001

System/Area: Fuel Cell Detank &

Safing SLS, SLF and CLS

NASA

Mfa/

PHN/ \$70-1225-03

Part No: 2201-888

Name: Pressure Gas Valve Pnl

James, Pond and Clark

79K15491 - Pg 1-2 Drawing/

Part No: 220T-888

Sheet No: 79K15493 - Pg 1-2

Function: Prevent reverse flow from the vehicle tanks into the GHe supply system.

Critical Failure Ende/Failure Hode No: Fail Closed/29PP129-001.006

Failure Causes: Contamination/Corresion

Failure Effect: Possible loss of the LH2 vent stack purge. Loss of purge when flowing H2 could result in an explosive mixture in the vent line, causing a fire or explosion with loss of life and/or vehicle. There is no method to detect loss.

Time to Effect: Issuediate

Acceptance Rationale

Design: Rated: Actual: Operating Pressure - 3000 PSI 275 PSI Proof Pressure - 4500 PSI **Burst Pressure** - 12000 PSI Operating Temp - 40°F to +250°F **Ambient** Body Material - 300 Series SST - 302 SST Spring Material Seal Material - Buna N and Teflon

All material in this Check Valve is compatible for use with dry air, helium, hydrogen and mitrogen.

HORKSHEET 5122-012 930224akN3SAA0067/E0

I - 419

+ 5050234AL of 22

պ<u>ե</u>գ**շջչ** ,

SAA29PP129-001

B/L: 72.06 72.63

SYS: Fuel Cell

Deservicing

MAY 1 9 1992

A106656 (Continued)

This Check Valve is designed to allow flow to occur with a maximum cracking pressure of 8 PSI and to remain bubble tight in the reverse flow direction over the entire range of inlet and outlet pressures.

<u>Test</u>: The manufacturer performs the following tests:

- Proof pressure test
- 8 PSI max. cracking pressure test ٥
- Leakage test

Inspection:

- CMRS 79K16224, requires this Check Valve to be leak checked at component replacement.
- File VI requires the vent stack purge flow to be verified audibly, prior to starting HZ drain operations.

Failure History:

- The PRACA database was queried and no failures in the critical failure mode were found.
- The GIDEP failure data interchange system has been researched and no failures of this component were found.

Operational Use:

o Corrective Action:

There is no action which can be taken to mitigate the failure effect.

Timeframe:

Since no corrective action is available, timeframe does not apply.

I - 420

14 SP50234AL .. 46 29